



BV LCIE
CHINA
Number

N° 1966AS07ZEM32289

ATTESTATION of conformity with European Directives

Product: PV inverter (Grid-tied photovoltaic inverter)
Reference GW50KLV-MT, GW80K-MT
Issued to JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD
Address NO.189 Kun Lun Shan Road Suzhou New District. Jiangsu, China
Manufacturer JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD
Technical characteristics See Next Page

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 62109-1: 2010	ZEM-19MY3305FCSHP-1	31/07/2019
EN 62109-2: 2011	ZEM-19MY3305FCSHP-2	31/07/2019

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China),), July 31th, 2019.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



Model / Type.....:	GW80K-MT	GW50KLV-MT
MPP DC voltage range	200-1000 V d.c	200-650 V d.c
MAX Input DC voltage	1100 V d.c	800 V d.c
Max Input DC current	44/44/44/44A	
Output AC voltage	3/N/PE~400V or 3/PE~400V 50/60Hz	3/PE or 3/N/PE~208V/220V/240V 50/60Hz
Max. Output AC current	133A	
Rated output power	80000W	50000W

Shanghai (P.R. China),), July 31th, 2019.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.